

**WATER QUALITY TESTING REPORT**  
Source: - Nehru Memorial Govt. H.S.School Aalo  
Date of testing: - 28/09/2026

| Sl no. | Parameter        | Range            | Report/ Result |
|--------|------------------|------------------|----------------|
| 1.     | Turbidity        | 0-100 NTU        | 0.3 NTU        |
| 2.     | PH               | 6.5 to 8.5 value | 7.1 Value      |
| 3.     | Total Alkalinity | 0-500 mg/l       | 50 mg/l        |
| 4.     | Chloride         | 0-50mg/l         | 2 mg/l         |
| 5.     | Chlorine         | 0-5 mg/l         | 0.001 mg/l     |
| 6.     | Fluoride         | 0-1.5 mg/l       | 0.002 mg/l     |
| 7.     | Total Hardness   | 0-500 mg/l       | 10 mg/l        |
| 8.     | Iron             | 0-1mg/l          | 0.001 mg/l     |
| 9.     | Nitrate          | 0-1ml/l          | 0.02 mg/l      |
| 10.    | Bacteriological  | Present/ Absent  | Absent         |

  
Lab Asstt.  
PHE & W/S Division  
Aalo.

  
Assistant Engineer  
PHE & WS Sub-Division  
Aalo

  
Principal  
Govt. N.M.H.SS, Aalo  
West Siang Distt. (A.P)